

Certificate

Reg.-No. K 1591 / 12.2014

The
confirms to the manufacturer
the compliance of the product

Certification Body of MPA Darmstadt

Peštan d.o.o.

1300 Kaplara br. 189, 34301 Bukovik, Arandelovac, Serbien

**Pipes for drinking water supply made of polyethylene
for alternative installation techniques
according to PAS 1075:2009-03**

**Manufacturing group 16, type 1 [made of
polyethylene with enhanced stress cracking resistance
(PE 100 RC)], SDR 11 and SDR 17, wall thicknesses up
to 55,8 mm**

When burstlining the service overpressure has to be limited to max. 5
bar for SDR 11 resp. max. 3,2 bar for SDR 17.

of the production plant
with the certification programme

Peštan d.o.o.

1300 Kaplara br. 189, 34301 Bukovik, Arandelovac, Serbien

ZP-424

Pipes made of polyethylene for alternative installation techniques

This certificate is granted based on the results of the continuous inspection by the inspection body of MPA Darmstadt. The continuous inspection involves:

- Supervision of factory production control,
- Product testing according to DVGW worksheet GW335-A2 and MPA Darmstadt CERT certification programme ZP-424.

Type test reports:

- MPA Darmstadt No. K 13 1995.5 and 6 dated 17.09.2014,
- Hessel Ingenieurtechnik Roetgen No. R14 01 2520-B (FNCT) dated 18.12.2014, No. R14 01 2740-B (FNCT) dated 03.12.2014, No. R14 01 2740-A (PLT+) dated 03.12.2014 and No. R14 01 2520-B (Penetration) dated 18.12.2014.

Therefore the manufacturer is authorized to mark the product with the MPA-CERT-sign according to the terms of MPA Darmstadt for the application of the MPA-CERT-sign.

This certificate is valid only in connection with the latest inspection report.

Darmstadt, 13.02.2018



Dr.-Ing. Petra Bender
Head of Certification Body



Dipl.-Ing. (FH) Ludwig Veith
Technical responsibility

This document represents the English translation of the original German certificate issued by MPA Darmstadt. Please note that German is the official language of certificates issued by MPA Darmstadt and only the German version is legally binding.



TECHNISCHE
UNIVERSITÄT
DARMSTADT



Deutsche
Akkreditierungsstelle
D-ZE-11048-01-00