



BULGARKONTROLA S.A.

**CARGO & DAMAGE SURVEYS, LABORATORY ANALYSES,
CONFORMITY ASSESSMENT & TECHNICAL INSPECTIONS,
MANAGEMENT SYSTEMS**



Head office: 23, Sitnyakovo Blvd., 1505 Sofia, Bulgaria
Emergency mobile: +359 889 400 400, Tel.: +359 2 989 4070, Fax: +359 2 988 2354
E-mail: sales@bulgarkontrola.bg, cert@bulgarkontrola.bg

CERTIFICATE OF CONFORMITY 14 - НСИОССП-2074

In accordance with part III of Ordinance with the essential buildings' requirements and conformity assessment of construction products (State Gazette 106/2006) it has been stated that the construction products

PIPES MADE OF HIGH DENSITY POLYETHYLENE (HDPE100) Black with blue stipe

Designed for construction of drinking water-supply pressure piping systems outside buildings and branching to buildings, with operating pressure and dimensions as given in Supplement №1 to this Certificate

PLACED ON THE MARKET BY PEŠTAN d.o.o.

34301 BUKOVIK – ARANJELOVAC, 1300 Kaplara, Serbia

MANUFACTURED BY PEŠTAN d.o.o.

34301 BUKOVIK – ARANJELOVAC, 1300 Kaplara, Serbia

are manufactured under the conditions of introduced by the manufacturer system for production control and are submitted by the manufacturer to ongoing testing of test specimens in accordance with a prescribed test plan.

The Conformity Assessment Directorate at Bulgarkontrola S.A. has performed initial type-testing, initial inspection of the production control and performs continuous surveillance, assessment and approval of the production control.

This Certificate attests that all provisions concerning the conformity assessment of the construction product and the requirements of

BDS EN 12201-2: 2011+A1:2013


were applied and fulfilled and that the product conforms to all prescribed requirements.

This certificate is rescind the certificate No 14-НСИОССП -1015 on 28/03/2012 and remains valid as long as the conditions laid down in the technical specification are fulfilled and the production conditions or the production control are not modified significantly.

Date: 14/04/2014
Sofia

Executive Director
/ N. Atanasov /

BULGARKONTROLA S.A. – Sofia with identification number 14
Permit № ПОССП-14/24.01.2008 г., issued by MRRB






Supplement № 1
to Certificate of Conformity № 14 – НСИСОСП - 2074

Nominal dimension DN/OD (mm)	SDR	Operating pressure PN (bar)
50 ÷ 630	27,6	6
25 ÷ 630	17	10
20 ÷ 500	11	16
16 ÷ 400	9	20

Date: 14/04/2014
Sofia

Executive Director:


/ N. Atanasov /



BULGARKONTROLA S.A. – Sofia with identification number 14
Permit № РОССП-14/24.01.2008 г., issued by MRRB