



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПООСП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – НУРВСПЦРБ – 4020

Issued pursuant to Art. 14, par.1 and par.2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

INSPECTION CHAMBERS MADE OF POLYPROPYLENE (PP)

With vertical ring of PP corrugated pipes with SN 8,

With inlet and outlet on the base

Are designed for for non-pressure underground drainage and sewerage systems with product range, dimensions and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

place on the market by

PEŠTAN d.o.o.

1300 Kaplara 189, 34301 Bucovik , Serbia

manufactured by

PEŠTA N d.o.o.

1300 Kaplara 189, 34301 Bucovik , Serbia

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS EN 13598-2:2020

BDS EN 13598-2:2020/NA:2022

*and item 25 of Annex 2 to item 2 of Order № 02-14-1329 from 03.12.2015
of the Minister of Regional Development and Public Works
amendment and addition by Order № RD-02-14-252 from 10.03.2021*

The certificate was issued on **26/07/2024** cancel the **Certificate № 14-НУРВСПЦРБ-3833 from 21/04/2023** and remains valid until **20/04/2026**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

Place: Sofia

Date: 26/07/2024

Director of "Conformity Assessment" Dept.

/T. Lyubenova/



1. Nominal dimension and stiffness of pipes

Product range	Външен диаметър/вход- изход d_n / \varnothing (mm)
Transition Inspection chamber with one inlet and one outlet on the base	d_n 315/ \varnothing 110. d_n 315/ \varnothing 160 d_n 400/ \varnothing 110. d_n 400/ \varnothing 160 d_n 400/ \varnothing 200 d_n 630/ \varnothing 200 d_n 630/ \varnothing 315
Collective Inspection chamber with one inlet and three outlet on the base	d_n 315/ \varnothing 110. d_n 315/ \varnothing 160 d_n 400/ \varnothing 110. d_n 400/ \varnothing 160 d_n 400/ \varnothing 200 d_n 630/ \varnothing 200 d_n 630/ \varnothing 315 d_n 1000/ \varnothing 250 d_n 1000/ \varnothing 315

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Appearance	Smooth and clean surface without pores According to item 6.1. of BDS EN 13598-2;2020 BDS EN 13598-2/NA:2022
Color	Orange According to item 6.2. of BDS EN 13598-2;2020 BDS EN 13598-2/NA:2022
Geometrical characteristics, mm - Outer /inside diameter , mm	400÷630 According to item 7.2.2 of BDS EN 13598-2;2020 BDS EN 13598-2/NA:2022
Resistance / Impact strength of the base	No cracks or other damages of the base According to item 8, tabl. 6 of BDS EN 13598-2;2020 BDS EN 13598-2/NA:2022
Waterproofing	No leaks According to item 9.2, table 15 of BDS EN 1401-1:2019 BDS EN 1401-1:2019/NA:2020

Place: Sofia
Date: 26/07/2024

Director of "Conformity Assessment" Dept.

/T. Lyubenova/

