



# BULGARKONTROLA

**BULGARKONTROLA SA -Sofia**

*Conformity Assessment Body for Construction Products*

*With identification number 14 and Permit № ПОССП-14 on 15.09.2016*

*Issued by Ministry of Regional Development and Public Works*

## CERTIFICATE OF CONFORMITY

**14 – НУРВСПСРБ – 4017**

Issued pursuant to Art. 14, par.1 and par.2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

**Pipes made of polypropylene random with fiber (PP-R/PP-GF/PP-R)**  
**trademark "Fluidterm"**

Are designed for construction of building installations for hot and cold water for drinking water supply, with operating pressure **PN 10/16/20/25 bar**, dimensions **dn 20 mm ÷ 110 mm** and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

place on the market by

**PEŠTA N d.o.o.**

**1300 Kaplara 189, 34301 Bucovik , Serbia**

manufactured by

**PEŠTAN d.o.o.**

**1300 Kaplara 189, 34301 Bucovik , Serbia**

This certificate certifies that the product has been evaluated and meets national requirements set out in

**BDS EN ISO 15874-2:2013**

**BDS EN ISO 15874-2:2013/A1:2018**

**BDS EN ISO 15874-2:2013/A2:2022**

**BDS EN ISO 15874-2:2013/NA:2024**

*and item 16 of Annex 2 to item 2 of Order № 02-14-1329 from 03.12.2015,  
of the Minister of Regional Development and Public Works*

The certificate was issued on **26/07/2024** cancel the Certificate № **14-НУРВСПСРБ-3827** from **21/04/2023** and remains valid for three years until **20/04/2026**, provided that the manufacturer ensures consistency of product characteristics and the conditions of production or production control have not been changed significantly.

**Place: Sofia**

**Date: 26/07/2024**

Director of "Conformity Assessment" Dept.

*[Signature]*  
**/T. Lyubenova/**

FC/CPNR -7-3.9/02

стр. 1/2



**1. Evaluated characteristics in accordance with national requirements**

Characteristics	Requirement to declare / border level
Appearance	Smooth and clean surface without pores, According to item 5.1. of BDS EN ISO 15874-2:2013 BDS EN ISO 15874-2:2013/ NA:2024
Colour	white, green, grey
Geometrical characteristics, mm	Group 1: $20 \leq dn \leq 63$ mm Group 2: $75 < dn \leq 110$ mm According to item 6.2, table 5,9 BDS EN ISO 15874-2:2013, BDS EN ISO 15874-2:2013/A1:2018 BDS EN ISO 15874-2:2013/ NA:2024
Hydrostatic strength, (95 °C/165 h)	no leaks and punctures over 165 h According to item 7, table 10 BDS EN ISO 15874-2:2013 BDS EN ISO 15874-2:2013/ NA:2024
Longitudinal revision, %	$\leq 2$ % without damage, according to item 8, table 13 BDS EN ISO 15874-2:2013, BDS EN ISO 15874-2:2013/A2:2022 BDS EN ISO 15874-2:2013/ NA:2024
Melt mass - flow rate (MFR), g/10min 230 °C/ 2,16 kg/10min	$\pm 30$ % between MFR the raw material and the pipe According to item 8, table 13 BDS EN ISO 15874-2:2013, BDS EN ISO 15874-2:2013/A2:2022 BDS EN ISO 15874-2:2013/ NA:2024
Impact resistance-Charpy method,% for pipes DN $\leq 25$ mm	$\leq 10$ % breaking samples, according to item 7.2, table 11 BDS EN ISO 15874-2:2013, BDS EN ISO 15874-2:2013/A2:2022 BDS EN ISO 15874-2:2013/ NA:2024
Impact resistance- round - the clock method for pipes DN $\geq 32$ mm	TIR $\leq 10$ % , according to item 7.2, table 11 BDS EN ISO 15874-2:2013, BDS EN ISO 15874-2:2013/A2:2022 BDS EN ISO 15874-2:2013/ NA:2024

Place: Sofia  
Date: 26/07/2024

Director of "Conformity Assessment" Dept.

  
/T. Lyubenova/

