

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Product	polyethylene (PE) pressure pipes
Type	PE100; DN/OD: 20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630, 710, 800; SDR 9 (PN20), SDR 11 (PN16), SDR 13,6 (PN12,5), SDR 17 (PN10), SDR 21 (PN8), SDR 26 (PN6)
Intended use(s)	for water supply, for sewerage and drainage under pressure
Performances	geometrical characteristics – conforms; elongation at break – conforms; resistance to hydrostatic pressure – conforms; longitudinal reversion – conforms
Manufacturer	Pestan d.o.o., 1300 Kaplara 189, 34301 Bukovik, Serbia
Manufacturing plant	Pestan d.o.o., 1300 Kaplara 189, 34301 Bukovik, Serbia
Requirements	LST EN 12201-2:2011+A1:2014

This certificate is issued having performed actions prescribed for system 1+ in STR 1.01.04:2015 and confirms that the product complies with requirements set out in this certificate.

Number	SPSC-9590
Date of issue	2022-04-08 (first issued on 2019-04-08)
Valid until	2025-04-08 (information www.spsc.lt)
Granted to	Pestan d.o.o., 1300 Kaplara 189, 34301 Bukovik, Serbia, company code 07652992

Director



Valdemaras Gauronskis

Copy No. 1 EN